

Display hidden notes to specifier. (Don't know how? Click Here)

Copyright 2008 - 2010 ARCAT, Inc. - All rights reserved

PART 1 GENERAL

- 1.1 SECTION INCLUDES
 - A. Safety and Security Window Film:
 - 1. Clear safety film. (Safety S40) (Safety S70) (Safety S80) (Safety S140) (Safety S20 Exterior) (Safety S40 Exterior) (Safety S70 Exterior)

1.2 RELATED SECTIONS

- A. Section 08 54 13 Fiberglass Windows.
- B. Section 08 60 00 Roof Windows and Skylights.
- C. Section 08 83 13 Mirrored Glass Glazing.
- D. Section 08 44 23 Structural Sealant Glazed Curtain Wall.

1.3 REFERENCES

- A. ANSI Z97.1 American National Standard for Safety Glazing Materials Used in Buildings -Safety Performance Specifications and Methods of Test.
- B. ASHRAE American Society for Heating, Refrigeration, and Air Conditioning Engineers; Handbook of Fundamentals.
- C. ASTM International (ASTM):
 - 1. ASTM D 882 Standard Test Method for Tensile Properties of Thin Plastic Sheeting.
 - ASTM D 1044 Standard Method of Test for Resistance of Transparent Plastics to Surface Abrasion (Taber Abrader Test).
 - 3. ASTM D 4830 Standard Test Methods for Characterizing Thermoplastic Fabrics Used in Roofing and Waterproofing.
 - 4. ASTM E 84 Standard Method of Test for Surface Burning Characteristics of Building Materials.
 - 5. ASTM E 903 Standard Methods of Test for Solar Absorbance, Reflectance and Transmittance of Materials Using Integrating Spheres.
- D. Consumer Products Safety Commission 16 CFR, Part 1201 Safety Standard for Architectural Glazing Materials.
- E. GSA-TS01 Standard Test for Glazing and Glazing Systems Subject to Airblast Loadings.
- F. NFRC 100/200 (Formerly ASTM E903) Standard Methods of Test for Solar Absorbance,

Reflectance and Transmittance of Materials Using Integrating Spheres.

G. ISO 16933, International Standard for Glass in Building: Explosion-resistant security glazing - Test and classification for arena air-blast testing.

1.4 PERFORMANCE REQUIREMENTS

- A. Safety Glazing Impact Performance:
 - 1. 400 ft-lbs impact resistance, meeting ANSI Z97.1 (Class A, Unlimited) or 16 CFR 1201 (Category 2) impact requirements with film applied on 1/4 inch annealed glass
- B. Blast Hazard Mitigation Performance:
 - 1. GSA Rating of "3B" / ASTM F1642 "Minimal Hazard" with minimum blast load of 6 psi and 41 psi*msec, on 1/4 inch (6 mm) single pane glass and film attachment system.
 - 2. GSA Rating of "2" with minimum blast load of 12 psi and 66 psi*msec, on 1 inch (25 mm) double pane glass and film attachment system.
 - 3. GSA Rating of "3B" with minimum blast load of 4 psi and 29 psi*msec, on 1/4 inch (6 mm) pane glass without film attachment system.
- C. Adhesion to Glass:
 - 1. Minimum 2 lbs/in peel strength per ASTM D3330 (Method A).
- D. Flammability: Surface burning characteristics when tested in accordance ASTM E 84, demonstrating film applied to glass rated Class A for Interior Use:
 - 1. Flame Spread Index: no greater than 25.
 - 2. Smoke Developed Index: no greater than 55.
- E. Abrasion Resistance:
 - 1. Film shall have a surface coating that is resistant to abrasion such that less than 5 percent increase of transmitted light haze will result when tested in accordance to ASTM D 1044 using 100 cycles, 500 grams weight, and the CS10F Calibrase Wheel.
- F. UV Light Rejection:
 - 1. Minimum of 99% UV light rejection (300 380 nm), per ASTM E903, as determined with film applied on 1/4 inch clear glass.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 Administrative Requirements.
- B. Product Data: Manufacturer's current technical literature on each product to be used, including:
 - 1. Manufacturer's Data Sheets.
 - 2. Preparation instructions and recommendations.
 - 3. Storage and handling requirements and recommendations.
 - 4. Installation methods.
- C. 3rd Party Test Report Submittal Requirements. Submit the following 3rd Party test reports indicating compliance with the test values listed in this section.
 - 1. Flammability Testing, ASTM E84.
 - 2. Film Properties Testing, ASTM D882.
 - 3. Abrasion Resistance Testing, ASTM D1044.
 - 4. Peel Strength Testing, ASTM D3330
 - 5. Puncture Strength Testing, ASTM D4830.
 - 6. Safety Glazing Impact Testing, ANSI Z97.1 or 16 CFR 1201.
 - 7. Blast Hazard Mitigation Testing, ASTM F1642 / F2912 and/or GSA-TS01-2003.
- D. Other Product Submittals:

- 1. Manufacturer's summary of 3rd Party Blast Hazard Mitigation Testing, ASTM F1642 / F2912 and/or GSA-TS01-2003
- E. Verification Samples: For each film specified, two samples representing actual film color and pattern.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: All primary products specified in this section will be supplied by a single manufacturer with a minimum of ten years experience.
 - 1. Provide documentation that the adhesive used on the specified films is a Pressure Sensitive Adhesive (PSA).
- B. Installer Qualifications: All products listed in this section are to be installed by a single installer with a minimum of five years demonstrated experience in installing products of the same type and scope as specified.
 - 1. Provide documentation that the installer is authorized by the Manufacturer to perform Work specified in this section.
 - 2. Provide a commercial building reference list of 5 properties where the installer has applied window film. This list will include the following information:
 - a. Name of building.
 - b. The name and telephone number of a management contact.
 - c. Type of glass.
 - d. Type of film and/or film attachment system.
 - e. Amount of film and/or film attachment system installed.
 - f. Date of completion.
- C. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
 - 1. Finish areas designated by Architect.
 - 2. Do not proceed with remaining work until workmanship, color, and sheen are approved by Architect.
 - 3. Refinish mock-up area as required to produce acceptable work.
- 1.7 DELIVERY, STORAGE, AND HANDLING
 - A. Follow Manufacturer's instructions for storage and handling.
 - B. Store products in manufacturer's unopened packaging until ready for installation.
 - C. Store and dispose of hazardous materials, and materials contaminated by hazardous materials, in accordance with requirements of local authorities having jurisdiction.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's recommended limits.
- 1.9 WARRANTY
 - A. At project closeout, provide to Owner or Owners Representative an executed current copy of the manufacturer's standard limited warranty against manufacturing defect, outlining its terms, conditions, and exclusions from coverage.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: 3M Window Film, which is located at: 3M Center Bldg. 0235-02-S-27; St. Paul, MN 55144-1000; Toll Free Tel: 866-499-8857; Tel: 651-733-2222; Fax: 651-737-3446; Email:request info (jemannix@mmm.com); Web:www.3m.com/windowfilm
- B. Substitutions: Not permitted.

2.2 CLEAR SAFETY AND SECURITY WINDOW FILM

- A. 3M Safety S80 (SH8CLARL): Optically clear polyester film with a durable acrylic abrasion resistant coating over one surface and a pressure sensitive adhesive over the other. The adhesive is pressure-activated, not water-activated, and forms a physical bond, not chemical bond, to the glass. The film may be laminated to other clear polyester film layers to achieve the desired thickness of the film.
 - 1. Physical / Mechanical Performance Properties:
 - a. Film Color: Clear.
 - b. Thickness: Nominal 8 mils.
 - c. Tensile Strength (ASTM D 882): 25,000 psi.
 - d. Break Strength (ASTM D 882): 200 lbs/in
 - 2. Uniformity: No noticeable pin holes, streaks, thin spots, scratches, banding or other optical defects.
 - 3. Variation in Total Transmission across the Width: Less than 2 percent over the average at any portion along the length.
 - 4. Identification: Labeled as to Manufacturer as listed in this Section.
 - 5. Solar Performance Properties: Film applied to 1/4 Inch (6 mm) thick clear glass.
 - a. Visible Light Transmission (ASTM E 903): 87 percent.
 - b. Ultraviolet Transmission (ASTM E 903): Less than 1 percent.
 - 6. Impact Resistance for Safety Glazing: Tested on 1/4 inch (6 mm) annealed glass.
 - a. Safety Rating (CPSC 16 CFR, Part 1201): Category II (400 ft.-lbs).
 - b. Safety Rating (ANSI Z97.1): Class A, Unlimited Size.
 - 7. Blast Hazard Mitigation:
 - a. GSA Rating of "3B" / ASTM F1642 "Minimal Hazard" with minimum blast load of 6 psi and 41 psi*msec, on 1/4 inch (6 mm) single pane annealed glass and 3M Impact Protection Adhesive film attachment system.
 - b. GSA Rating of "3B" with minimum blast load of 7 psi and 41 psi*msec, on 1/4 inch single pane annealed glass and 3M Impact Protection Profile film attachment system.
 - c. GSA Rating of "3B" with minimum blast load of 4 psi and 29 psi*msec, on 1/4 inch single pane annealed or tempered glass without use of film attachment system.
 - d. GSA Rating of "2" with minimum blast load of 12 psi and 66 psi*msec, on 1 inch double pane annealed glass and 3M Impact Protection Adhesive film attachment system.
 - e. GSA Rating of "3B" with minimum blast load of 14 psi and 63 psi*msec, on 1 inch double pane annealed glass and 3M Impact Protection Profile film attachment system.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Film Examination:
 - 1. If preparation of glass surfaces is the responsibility of another installer, notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions.
 - a. Glass surfaces receiving new film should first be examined to verify that they are free from defects and imperfections, which will affect the final appearance.
 - 2. Do not proceed with installation until glass surfaces have been properly prepared and

deviations from manufacturer's recommended tolerances are corrected. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result under the project conditions.

3. Commencement of installation constitutes acceptance of conditions.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Refer to Manufacturer's installation instructions for methods of preparation for Impact Protection Adhesive or Impact Protection Profile film attachment systems.

3.3 INSTALLATION

- A. Film Installation, General:
 - 1. Install in accordance with manufacturer's instructions.
 - 2. Cut film edges neatly and square at a uniform distance of 1/8 inch (3 mm) to 1/16 inch (1.5 mm) of window sealant. Use new blade tips after 3 to 4 cuts.
 - Spray the slip solution, composed of one capful of baby shampoo or dishwashing liquid to 1 gallon of water, on window glass and adhesive to facilitate proper positioning of film.
 - 4. Apply film to glass and lightly spray film with slip solution.
 - 5. Squeegee from top to bottom of window. Spray slip solution to film and squeegee a second time.
 - 6. Bump film edge with lint-free towel wrapped around edge of a 5-way tool.
 - 7. Upon completion of film application, allow 30 days for moisture from film installation to dry thoroughly, and to allow film to dry flat with no moisture dimples when viewed under normal viewing conditions.
 - 8. If completing an exterior application, check with the manufacturer as to whether edge sealing is required.

3.4 CLEANING AND PROTECTION

- A. Remove left over material and debris from Work area. Use necessary means to protect film before, during, and after installation.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. After application of film, wash film using common window cleaning solutions, including ammonia solutions, 30 days after application. Do not use abrasive type cleaning agents and bristle brushes to avoid scratching film. Use synthetic sponges or soft cloths.

END OF SECTION